



**Wastewater Treatment Utility**  
 500 South River Road  
 West Lafayette, Indiana 47906  
 Voice: (765) 775-5145  
 Fax: (765) 775-5149

## MONTHLY REPORT OF OPERATIONS

### National Pollutant Discharge Elimination System -- NPDES

#### October 2013--MONTHLY AVERAGES

#### Limit

TSS	3.4	mg/l	(30.00)
CBOD	2.9	mg/l	(25.00)
NH <sub>4</sub>	0.1	mg/L	(6.00)
Cl <sub>2</sub>	0.02	mg/L	(0.06)
E. COLI	18	#/100ml	(125.00)
FLOW	TOTAL	214.2	MG
	AVG	6.91	MGD
	MAX	14.46	MGD
	MIN	5.73	MGD
PRECIPITATION	10.22	INCHES	

#### October 2013--PERCENT REMOVALS

TSS	98.1	REPORT ONLY
CBOD	98.4	REPORT ONLY
Ammonia	99.6	REPORT ONLY
Phosphorus	29.1	REPORT ONLY

#### COMBINED SEWER OVERFLOWS

October 2013	MG	HOURS	Events
<b>TOTAL FLOW</b>	<b>215.28</b>		
<b>PERCENT TREATED</b>	<b>99.5002</b>		
<b>OVERFLOW POINT</b>			
<b>DEHART STREET</b>	0.0120	7.67	4
<b>QUINCY STREET</b>	0.0040	1	3
<b>Wet Weather Treatment Facility</b>	1.0600	2.33	2
<b>OVERFLOW TOTAL</b>	<b>1.0760</b>	<b>11.00</b>	<b>9</b>