

April 30, 2014

Tecton Construction
102 N 3rd St, #201
Lafayette, IN 47901

Reference: City Hall Equipment

Mr. Witteveen,

I have the following to offer for you in regards to the equipment at City Hall;

- 1. AHU –
 - a. Age
 - i. AHU #1 (Basement) – 1986
 - ii. AHU #2 (1st Floor) – 1986
 - iii. AHU #3 (2nd Floor) – 1986
 - b. Size
 - i. AHU #1 (Basement) – 12.5 tons
 - ii. AHU #2 (1st Floor) – 20 tons
 - iii. AHU #3 (2nd Floor) – 20 tons
 - c. Model
 - i. AHU #1 (Basement) – 40RS-014-560
 - ii. AHU #2 (1st Floor) – 40RS-024---010
 - iii. AHU #3 (2nd Floor) – 40RS-024---010
 - d. Serial #
 - i. AHU #1 (Basement) – Y691500
 - ii. AHU #2 (1st Floor) – X796061
 - iii. AHU #3 (2nd Floor) – ~~??~~ N/A
 - e. CFM
 - i. AHU #1 (Basement) – ?? 3,000 – 5,000 CFM
 - ii. AHU #2 (1st Floor) – ?? 6-10,000
 - iii. AHU #3 (2nd Floor) – ?? 6-10,000 CFM

2. Fresh Air

- a. % per Unit
 - i. AHU #1 (basement) – 0 %
 - ii. AHU #2 (1st Floor) – 0 %
 - iii. AHU #3 (2nd Floor) – < 10%

3. Occupancy Count

- i. Basement – 3 (Plus storage)
- ii. 1st Floor – 12 (Plus court room capacity ⁵ 168
- iii. 2nd Floor – 18 (Plus conference room)

4. Boiler Age - 1983

Model #: GB-7

5. Chiller Age - 2000

Model #: AGZ040AS42ER10

Serial #: STNU010200101