



Wastewater Treatment Utility
 500 South River Road
 West Lafayette, Indiana 47906
 Voice: (765) 775-5145
 Fax: (765) 775-5149

MONTHLY REPORT OF OPERATIONS

National Pollutant Discharge Elimination System -- NPDES

October 2014--MONTHLY AVERAGES

Limit

TSS	4.7	mg/l	(30.00)
CBOD	3.3	mg/l	(25.00)
NH ₄	0.12	mg/L	(6.00)
Cl ₂	0.02	mg/L	(0.06)
E. COLI	29	#/100ml	(125.00)
FLOW	TOTAL	287	MG
	AVG	9.26	MGD
	MAX	19.86	MGD
	MIN	6.86	MGD
PRECIPITATION	6.17	INCHES	

October 2014--PERCENT REMOVALS

TSS	97.1	REPORT ONLY
CBOD	97.6	REPORT ONLY
Ammonia	99.4	REPORT ONLY
Phosphorus	26.5	REPORT ONLY

COMBINED SEWER OVERFLOWS

October 2014	MG	HOURS	Events
TOTAL FLOW	298.21		
PERCENT TREATED	96.2399		
OVERFLOW POINT			
DEHART STREET	0.0181	12.92	5
QUINCY STREET	0.4210	10.17	5
Wet Weather Treatment Facility	10.7740	9.18	6
OVERFLOW TOTAL	11.2131	32.27	16