



Wastewater Treatment Utility
 500 South River Road
 West Lafayette, Indiana 47906
 Voice: (765) 775-5145
 Fax: (765) 775-5149

MONTHLY REPORT OF OPERATIONS

National Pollutant Discharge Elimination System -- NPDES

June 2015--MONTHLY AVERAGES

Limit

TSS	5.3	mg/l	(30.00)
CBOD	2.8	mg/l	(25.00)
NH ₄	0.09	mg/L	(6.00)
Cl ₂	0.03	mg/L	(0.06)
E. COLI	9	#/100ml	(125.00)
FLOW	TOTAL	334.27	MG
	AVG	11.14	MGD
	MAX	21.17	MGD
	MIN	5.15	MGD
PRECIPITATION	8.94	INCHES	

June 2015--PERCENT REMOVALS

TSS	95	REPORT ONLY
CBOD	96.1	REPORT ONLY
Ammonia	99.1	REPORT ONLY
Phosphorus	32.8	REPORT ONLY

COMBINED SEWER OVERFLOWS

June 2015	MG	HOURS	Events
TOTAL FLOW	344.66		
PERCENT TREATED	96.9854		
OVERFLOW POINT			
DEHART STREET	0.6000	12.91	6
QUINCY STREET	0.7900	5.08	6
Wet Weather Treatment Facility	9.0000	8.8	6
OVERFLOW TOTAL	10.3900	26.79	18