


Supplemental Information

* Included in this section of the report are as follows:

- Natural Light Readings Sheet N-1
- Existing Mechanical Equipment Age Summary
- Mold Prevention Pamphlet
- Wall System Dew Point Article
- Wall System Thermal Design
- Trouble Shooting Masonry Walls Article
- Moisture Management Weep Holes Article
- Architectural Metal Panels Wall Examples
- R-Value Ratings Reference Information

WEST LAFAYETTE CITY HALL INSPECTION REPORT



Natural Light Readings N-1

(12 Noon Reading Time)

<u>Reading (foot Candles)</u>	<u>Location</u>	<u>Notes</u>
5.3 fc	West Lafayette City Hall, 2 nd Floor Office (North)	Middle of Office with Window, No Shades
19 fc	West Lafayette City Hall, 2 nd Floor Office (East)	Middle of Office Directly In Front of Windows, No Shades
33 fc	West Lafayette City Hall, 2 nd Floor Hall (North)	10' From Full Height Glass Wall
3.7 fc	West Lafayette City Hall, 1 st Floor Council Chamber	10' From Windows, No Shades
25 fc	West Lafayette City Hall, 2 nd Floor Office (South)	Middle of Office Directly in Front of Window, No Shades
30-50 fc	Typical Office Total Lighting Required (Natural Light + Artificial Light)	Dependent Upon Task